Declarație de performanță Actulux SVM EI control panel — EN

Document oficial al producătorului Actulux, reprodus integral și nemodificat în paginile următoare.

Furnizor în România: HSL Solutions SRL

Str. Sinaia, Nr. 25-29, Ștefănești de Jos, Jud. Ilfov

contact@ventio.ro · www.ventio.ro · 0762.921.795

VENTIO este o marcă HSL Solutions SRL

TYPE EXAMINATION CERTIFICATE

C901003

Smoke and Heat Control Systems "Actulux SVM-EI", "Actulux SVM Micro"

Issued to

Actulux A/S

Porsborgparken 35, DK-9530 Støvring, Denmark

Product name

Actulux SVM-EI 24V-5A, SVM-EI 24V-8A, SVM-EI 24V-10A, SVM Micro 24V-4A, SVM Micro TCE 24V-4A. All models equipped with casing in plastic or metal.

Product description

Smoke and heat control systems: Type D, electrical control panel with direct connection for detectors. Can be used for Comfort Ventilation. The panel can be equipped with an m.c.p, or shall be connected to an external m.c.p. Software version 1.014 (SVM-EI).

Certificate

The products described in this certificate have been type-examined by RISE and found to fulfil the requirements set out in standard ISO 21927-9:2012. Basis for this certificate is test reports no. P115623.DP01.A01_SVM-EI, P122282.DP01.A01, P122608.DP01.A01, Assessment O100436_A05_18, issued by RISE Research Institutes of Sweden AB, Unit: *Electrification and Reliability - Safe Control Systems* and Assessment P126785.DP01.A01, issued by RISE Research Institutes of Sweden AB Unit: *System- and product safety - System validation*

Specification:

Operational Reliability: **Re 1000**
Environmental class: **1**

Marking

Each product that conforms in all respects with the original item type-examined may display the text 'Type examined by RISE'. When this marking is applied the marking shall also contain the information required by the actual standard, the number of this certificate and the serial number or equivalent of the item.

Validity

This certificate is valid until not later than 2028-11-16. The validity of this certificate can be verified by RISE.

Miscellaneous

Other terms and conditions are set out in RISE certification rule, SPCR 123, Certification rules for type-examination certificate. The certificate was originally issued on 2023-11-16. This issue replaces all earlier issues.

Martin Tillander

Certificate C901003 | issue 5 | 2026-05-13

RISE Research Institutes of Sweden AB | Certification
Box 857, SE-50115 Borås, Sweden
+46 10 516 50 00 | certifiering@ri.se | www.ri.se

2026-03-20
1366177
This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE